

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003
P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562



**Sample Number
LH50767**

Official Laboratory Report

Report To: CITY OF MARYSVILLE
1535 RIVER RD
MARYSVILLE MI 48040

System Name/Owner:	CITY OF MARYSVILLE	WSSN/Pool ID:	4160
Collection Address:	1535 RIVER RD, MARYSVILLE	Source:	TYPE I
Collected By:	CHRIS BERDAN	Site Code:	TP100
Township/Well#/Section:	//	Collector:	Other
County:	St Clair	Date Collected:	11/01/2017 09:00
Sample Point:	PLANT TAP	Date Received:	11/02/2017 10:52
Water System:	Pressure Tank/Plant Tap	Purpose:	Other

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Lead	Not detected	11/06/2017	0.001	0.015	EPA 200.8	7439-92-1

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

**St. Clair County Health Dept.
3415 28th St.
Port Huron, MI 48060
810 987-5306**

CAS# : Chemical Abstract Service Registry Number
MCL : Maximum Contaminant Level
AL : Action Level
RL : Reporting Limit

mg/L : milligrams / Liter (ppm)
ppm : parts per million
MPN : Most Probable Number
CFU : Colony Forming Unit

Laboratory Contact: Scott Hayward