

**Bari Wrubel**

---

**From:** Bolt, Jennifer (DEQ) <BOLTJ@michigan.gov>  
**Sent:** Wednesday, November 1, 2017 12:28 PM  
**To:** Bari Wrubel; Johnson, Stephanie (DEQ)  
**Subject:** 2017 Lead and Copper Monitoring Results

Bari,

Per your request, here is a preliminary copy of Marysville's 90<sup>th</sup> percentile for lead and copper for the June-September 2017 monitoring period. An official letter will be sent to the supply later this year.

The Michigan Department of Environmental Quality (DEQ), Drinking Water and Municipal Assistance Division (DWMAD), received your 2017 lead and copper monitoring results, reporting form, and certification of lead consumer notice. The results of your monitoring are as follows. Please note that lead is reported in parts per billion (ppb) and copper in parts per million (ppm) to correspond with the Consumer Confidence Report reporting requirements. Please retain for your records.

WSSN: 4160    Supply Name: Marysville


Action Levels	90 <sup>th</sup> Percentile	# of Samples Above Action Level
Lead 15 parts per billion (ppb)	6 ppb	0
Copper 1300 parts per billion (ppm)	0 ppb	0

If the result for either lead or copper is greater than 0 ppb, it must be reported on your 2017 Consumer Confidence Report (CCR) due to our office, your customers, and the local health department by July 1, 2018. Also include the following statement in the CCR, regardless of the lead and copper levels:

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://water.epa.gov/drink/info/lead>.*

Please contact me if you have any questions, at 517-284-5615 or boltj@michigan.gov.

Thank you,



Jeni Bolt