



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING



C. HEIDI GRETHER
DIRECTOR

January 30, 2018

Mr. Bari Wrubel
City of Marysville
1535 River Road
Marysville, Michigan 48040

WSSN: 04160
County: St. Clair
Supply: City of Marysville

Dear Mr. Wrubel:

Subject: Lead and Copper Monitoring of Drinking Water Taps

The Michigan Department of Environmental Quality (MDEQ) received your results of lead and copper tap monitoring conducted between June 1 and September 30, 2017. The calculated ninetieth percentile values are listed below. Please retain this information for your records.

Action Levels	90 th Percentile Value	# of Samples Above Action Level
Lead 15 parts per billion (ppb)	6.0 ppb	0
Copper 1.3 parts per million (ppm)	0.0 ppm	0

If the result for either lead or copper is greater than 0 ppb, it must be reported on your 2017 Consumer Confidence Report, due to our office, your customers, and the local health department by **July 1, 2018**. The following statement must also be included in the Consumer Confidence Report, regardless of the lead and copper levels:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://water.epa.gov/drink/info/lead>.

Mr. Bari Wrubel
Page 2
January 30, 2018

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING



If you have questions, please contact me at 517-284-5413; jacksonh@michigan.gov; or Technical Support Unit, Drinking Water and Municipal Assistance Division, MDEQ, P.O. Box 30817, Lansing, Michigan 48909-8311

Sincerely,

Heather Jackson
Environmental Quality Analyst
Drinking Water and Municipal
Assistance Division

Action Level	90th Percentile Value	# of Samples Above Action Level
Lead 15 parts per billion (ppb)	6.0 ppb	0
Copper 1.3 parts per million (ppm)	0.0 ppm	0

If the result for either lead or copper is greater than 0 ppb, it must be reported on your 2017 Consumer Confidence Report, due to our office, your customers, and the local health department by July 1, 2018. The following statement must also be included in the Consumer Confidence Report regarding the lead and copper levels:

If present, elevated levels of lead can cause serious health problems especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the State Drinking Water Hotline at 1-800-426-4791 or at <http://water.epa.gov/drink/lead>.